

APPENDIX 1. NOTIFICATION TEMPLATE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Nitrate Monitoring Requirements Not Met for SIERRA HIGH SCHOOL during 2021

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2021, we did not monitor or test for nitrate from the sources listed in the table below and therefore, cannot be sure of the quality of our drinking water during that time.

Source Name	Primary Station Code
WELL 01 - RAW	CA1000280_001_001
WELL 02 - RAW	CA1000280_002_002

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the last year, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.
- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples will be taken
Nitrate	Minimum is one sample annually from each active raw water source	None	During calendar year 2021	2-14-2022